



**GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE**



From: The District fire officer,
Khammam Division.

To: POPURI RAVI MARUTH,
H.NO :- 7-300,
SY.NO.134/2,
SAI KRISHNA NAGAR,
NEAR RAJIV SWAGRUHA VICINITY,
POLEPALLI (VIL),

Rc. No.454600002022 Dated:25/06/2022

Sir,
Sub: TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT —Khammam Division.
Issue of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **LITTLE ANGELS HIGH SCHOOL PROGRESSIVE EDUCATIONAL SOCIETY, H.NO :- 7-300, SY.NO.134/2, SAI KRISHNA NAGAR, NEAR RAJIV SWAGRUHA VICINITY, POLEPALLI (VIL) /- Polepalle/Khammam (Rural)/Khammam, Hyderabad – Regarding.**



Ref: 1. Acknowledgement No 454600002022 dt.25/06/2022
2. Inspection Committee Report, Acknowledgement No: 454600002022

1. The Multi Storeyed Building Inspection committee, vide reference cited (2) have inspected the Non Multi Storeyed Building of **LITTLE ANGELS HIGH SCHOOL PROGRESSIVE EDUCATIONAL SOCIETY, H.NO :- 7-300, SY.NO.134/2, SAI KRISHNA NAGAR, NEAR RAJIV SWAGRUHA VICINITY, POLEPALLI (VIL) /- Polepalle/Khammam (Rural)/Khammam** and submitted the following report.

2. The above building was constructed without obtaining the Provisional Noc from this department and now the builder submited application for issuance of No Objection Certificate for occupancy to the existing buliding of **Ground, 2 Floors**, with a height of **9.90 Meters** for **EDUCATIONAL B-1 Schools** up to senior secondary level.

3. Open Spaces : The builder provided the following open spaces all around the building.

Sl.No	Side	Open space Required as per Supreme Court's order on W.P.No.483 of 2004	Open space Provided
1	North	6.00	6.60
2	South	6.00	6.00
3	East	6.00	19.83
4	West	6.00	6.00
5	Front Direction	East	

4. Means of Access :

SI. No	Gate Width As per NBC 2016	Required	Provided
1	Entry gate width	6.00	6.0
2	Exit Gate Width	6.00	6.0
3	Entry Gate Head Clearance	4.50	4.50
4	Exit Gate Head Clearance	4.50	4.50

5. Travel Distance

Sl. No.	Item / Description	Required (Not More than in Mtrs.)	Provided
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	14.95
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational,	6.00	5.50

Institutional and Assembly, 15mtrs for other Occupancies)

6. Stair Cases (As per NBC 2016)

Sl.no.	Type of staircases	Width (In Mtrs)	No of staircases	Floors from	Floors to
1	Internal staircases	1.50	2	Ground	2nd Floor

7. Means of Escape Floor Wise Details

Sl.no	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per table 21 of NBC	Means of escape Provided
1	Ground	696.51	EDUCATIONAL B-1 Schools up to senior secondary level	174.00	1.74	3.00
2	1st Floor	626.82	EDUCATIONAL B-1 Schools up to senior secondary level	157.00	1.57	3.00
3	2nd Floor	626.82	EDUCATIONAL B-1 Schools up to senior secondary level	157.00	1.57	3.00

8. Floor Wise details of Fire Fighting Installations.

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automatic detection and alarm system
1	Ground	4.00	1.00	0.00	0.00	0.00
2	1st Floor	4.00	1.00	0.00	0.00	0.00
3	2nd Floor	4.00	1.00	0.00	0.00	0.00

9. Fire Fighting Installations as per Table 7 of NBC 2016:

Fire Fighting System.	Required As per NBC	Provided
Fire Extinguishers	12.00	12
First Aid Hose Reel	3.00	3
Capacity of Terrace Tank over Respective Tower Terrace in Litres	10000.00	10000
Pump capacity in LPM at the Terrace Tank level with min Pressure of 3.5 Kg/CM ²	450.00	450
No. of Terrace Tanks over Respective Tower in ltrs	1	1
No. of Pumps at the Terrace Tank level with min pressure of 3.5 Kg/Cm ²	1	1

10. The builder has provided the following additional Fire Safety Requirements as per NBC of India 2016 as per NBC part 4 of India 2016::

Sl. No	Fire safety Item
1.	Open spaces all around the building are Leveled and have hard open spaces for the operation of fire vehicles.
20	Fire extinguishers / fixed fire fighting installations, static water storage tanks and pump house are Complied with Clause 5.1 of part – 4 NBC of India 2016
21	Automatic sprinkler installation shall be complied with as per Clause 5.1.3 of part – 4 NBC of India 2016 (If Basement exceeds 200 sq. Mtr. Area)
22	Fire Safety plans prepared and submitted by the builder.
23	Fire Drills shall be conducted with accordance with the fire safety plan at least once in every 03 months for building during the first 02 Years and there after once in 6 months as per Clause D-3 in annex. D of Part IV NBC of India 2016.

11) In view of the above and as per recommendations of the multistoried building inspection Committee, the No Objection Certificate for occupancy is issued to Multi Storied Building with

Sl No	As Builder	As occupant	As Security Personnel

1	-All the fire protection arrangements shall be maintained in good condition as seen during inspection. -Do's and Don't in case of fire shall be prominently displayed in entire building	All the escape/exit roots shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for five year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If Not, take all steps to isolate the area by closing doors and windows.

This No Objection Certificate for Occupancy is valid for Five years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Yours Sincerely,
District fire officer,
Khammam Division.

Copies to:

- i) The Management
- ii) Multistoried Building Inspection Committee
- iii) Copy submitted to Regional Fire officer
- iv) Copy submitted to DG fire services.

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"

M. Pandirajam
PRINCIPAL
Harvest Spring Leaf School
Karunagiri, KHAMMAM

P. Ravi Kumar
MANAGER
Harvest Spring Leaf School
Khammam



41
GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT
APPROVAL FOR CHANGE OF NAME OF THE ESTABLISHMENT



From
The District fire officer,
Khammam Division.

To,
POPURI RAVI MARUTH,
H.NO :- 7-300,
SY.NO.134/2,
SAI KRISHNA NAGAR,
NEAR RAJIV SWAGRUHA VICINITY,
POLEPALLI (VIL) ,

Ack. No. 48100002023 Dated: 21/03/2023

Sir,

Sub:

TELANGANA STATE DISASTER RESPONSE & FIRE SERVICE DEPARTMENT —Khammam Division.
Application for change of name of the Establishment **LITTLE ANGELS HIGH SCHOOL** in Sy.No. H.NO :- 7-300, SY.NO.134/2, SAI KRISHNA NAGAR, NEAR RAJIV SWAGRUHA VICINITY, POLEPALLI (VIL) , situated at Polepalle Village, Khammam (Rural) Mandal, Khammam District-Permission accorded for change of name in our official Correspondences Regd.



Ref:

1. Online Application Acknowledgement No 48100002023
2. This office NOC for Occupancy with Rc. No. 45460002022
3. Sworn in Affidavit in support of rightful authority of the Applicant dt. 21/03/2023

- 1) Vide reference 2nd cited, the existing/proposed Multi Storeyed Building/Non Multi Storeyed Building **LITTLE ANGELS HIGH SCHOOL** located in Sy. No. H.NO :- 7-300, SY.NO.134/2, SAI KRISHNA NAGAR, NEAR RAJIV SWAGRUHA VICINITY, POLEPALLI (VIL) , situated at Polepalle Village Khammam (Rural) Mandal, Khammam District was issued Occupancy NOC for **Ground, 2 Floors**, floors with a height of **9.90** meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy.
- 2) Vide reference 1st cited, the builder/owner of the above said establishment stated that he is the authorized person on behalf of it and requested to change the name of that establishment in our official correspondences. He also submitted the documental evidences of the change of name of the establishment were in online.
- 3) In view of the above and based on the documental evidences submitted by the applicant , the request for name Change of the above establishment as **HARVEST SPRING LEAF SCHOOL** located in Sy. No.H.NO :- 7-300, SY.NO.134/2, SAI KRISHNA NAGAR, NEAR RAJIV SWAGRUHA VICINITY, POLEPALLI (VIL) , situated at Polepalle Village, Khammam (Rural) Mandal, Khammam District with a height of **9.90** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy is here by permitted in all our official correspondences henceforth. All the terms and conditions and other data mentioned in Occupancy NOC remain unchanged.
- 4) This document does not confer any legal right for claiming titleship of property or Conversion of land use/Occupancy or Building Regularization.

Yours Sincerely,
District fire officer,
Khammam Division.

Copies to:

- i) The Management
- ii) Multistoried Building Inspection Committee

M. Parthasarajam
PRINCIPAL
Harvest Spring Leaf School
Karunagiri, KHAMMAM

P. Ravi Maruth
MANAGER
Harvest Spring Leaf School
Khammam